

Kinetic Micro Hydro for Telecommunication Sites






Agenda

- Pico hydropower as alternative source for remote cell sites
- Smart Hydro Power Product Description
- Business Case
 - Diesel
 - Grid injection
- Usage Case
- Site Analysis
- Market Potential
- Status Smart Hydro Power & next steps

GSMA analysis with positive result for pico hydro – but lack of suppliers



Source: GSMA Analysis

*Assuming fuel is constant **Assuming purchase of biofuel from supplier ***Fuel cell CAPEX forecast to improve rapidly



Hydropower is baseload energy

Technology	Usage hours India*	Usage hours Germany*
Photovoltaic	2,500 h	800 h
Wind power	3,500 h	2,500 h
Hydropower	8,300 h	8,300 h



* Typical sites, strong variation



First standardized 5 kW turbine designed for off-grid applications



- Complete Unit (plug & play)
- 340 kg weight allows easy installation
- Robust, industrial assembling
- Adaptable to local environment
 - 50 Hz / 60 Hz
 - 110 / 220 Volt
 - Grid injection / isolated grid

Smart kinetic hydropower is environmental friendly...



- No changes to river habitat (no dam, easy removable)
- Water safe materials only
- No noise (Operates quietly)
- Fish friendly due to lack of suction in front of the turbine
- If substituting diesel standardized units fit CDM program approach

🐟 ...and easy to handle

Crane




Trailer

Carry





Power output at different speeds



Even low velocities enough for base load supply of small sites

Example:

- Remote RV Park w/o Grid no coverage
- 50 Sites for Campers
- 100 People Friday – Sunday
- 20 calls at the same time.



Case recreational area small: 1/1/1 RRH 20

Additional load MW typical:

Additional load summer/winter

(CBU Battery Cooler 12V/ 2V Battery)

➔ 725 W

➔ 90 W

➔ 50/45 W


Total

➔ 865 W



Business case (1): Smart vs diesel

Price Diesel in India (Rupee / l)



kWh_{electric} from diesel genset

Diesel 0.73 U\$ / l

Transport (x50%) 0.37 U\$ / l

Total 1.10 U\$ / l

Electric efficiency 30%

= 0,37 U\$ / kWh_{el}

Capex	18,000 U\$
Amortisation period	5 years
Life cycle	10 years
Opex (p.y.)	500 U\$
Usage hours	8,300 h

1,0 kW 0,50 U\$ / kWh

1.5 kW 0,33 U\$ / kWh

2.0 kW 0,25 U\$ / kWh

3,0 kW 0,17 U\$ / kWh

5,0 kW 0,10 U\$ / kWh



Business case (2): Smart to the grid

- Capex 16,500 U\$
- Amortisation period 10 years
- Life cycle 10 years
- Opex 750 U\$
- Usage hours 8300 h
- Annual costs 2400 U\$

Power output	kWh generated	Specific cost
1 kW	8,300 kWh	0,28 U\$ / kWh
1,5 kW	12,000 kWh	0,20 U\$ / kWh
2 kW	16,000 kWh	0,15 U\$ / kWh
3 kW	24,000 kWh	0,10 U\$ / kWh
5 kW	41,000 kWh	0,05 U\$ / kWh

Feed-in tariff
India (PV)
0,17 U\$/kWh
(average bid
price 2012)



Huge market potential India

River name	BCM(Billion cubic meters)/Ann	Average Flow m3/sec ⁺	Place of measurement*	Height (m)*	Width (m) [#]	Average linear flow (m/s)
Ganga	250,00	7927,447996	Farakka barrage	3,5	1106	2,05
Brahmaputra	240,00	7610,350076	Lakhipur	5	805	1,89
Godavari	76,30	2419,457128	Polavaram	8,5	186	1,53
Krishna	58,00	1839,167935	Dameracherla	7,5	137	1,79
Cauvery	19,00	602,4860477	Menaangudi	3	125	1,61
Mahanadi	49,99	1585,172501	Basantpur	7,5	168	1,26
Narmada	34,50	1093,987823	Koyali	6	146	1,25
Tapi	14,50	459,7919838	Sinor	4	118	0,97
Indus (up to Border)	46,00	1458,650431	NA			

Rivers to be used for Power generation

- Source: own analysis based on water related statistics(central water commision)+ Integrated Hydrological data book 2009* Google earth

Status and next steps

Installed Turbines

- Auermühlbach, Munich, Germany
- Hoyobamba, San Martin, Peru
- Elbe, Wittenberge, Germany
- Canal Perlen Papier AG, Perlen, Switzerland

Current Planning

- Rhine, Bingen, Germany, modular 80 kW power plant
- Kaptai Dam, Chittagong, Bangladesh, modular >100 kW plant
- Rhine, Bonn, Germany
- Papua, Indonesia

Future Projects

- Telecommunication towers?




© SMART HYDRO POWER GmbH

Dr. Karl Reinhard Kolmsee, Managing Director
Alte Traubinger Str. 17, 82340 Feldafing, Germany
karl.kolmsee@smart-utilities.de



Velocity
Streamline all
3.000e+00
2.250e+00
1.500e+00
7.500e-01
0.000e+00
[m s⁻¹]





Backup




How to find the appropriate sites

- Identify rivers with velocity > 1.5 m/s
- Match with existing / planned cell sites
- Match current demand / supply potential
- Shape demand curve if possible / needed
- Find customer for excess energy



Example II – Swiss: Survey of potential cellsites for grid connection



Summary:

- Cell sites within 200m next to the river could be powered by hydro turbine
- It is possible to locate cell sites near the river

Business model:

- Operator could be interested to use cell sites for getting the feed in tariff / Cell sites can be utilized as an connection point toward the grid

🐟 Basic Technical Overview

Physical Characteristics


- Weight: 340 kg
- Dimension: 1470x1740x1970 (LxWxH)
- Rotor diameter: $\varnothing 1000\text{mm}$
- Rotational Speed: 90 to 230 rpm (nominal)

Electrical Specifications

- Max Output Power: 5kW
- Electrical Rating: 5kVA
- Output Voltages: 230V /118V AC (24V DC possible)
- Operating Frequency (AC): 50Hz/60Hz
- Generator: Permanent Magnet Synchronous AC

River Specifications

- Min depth 2 m
- Recommended velocity $> 1,5 \text{ m / s}$, $< 3,5 \text{ m / s}$





Certifications

Available Now

EU - CE:

- EN ISO 12100 2010: Safety of machines
- DIN EN 60204-1 206 + A1 2009: low voltage regulation
- EN 1037: 1995 + A1 2008: Safety of machines
- EN 349 1993 + A1 2008: Protection of human damages

EN ISO 13857 2008: Safety of machines

EN 953 1997 + A1 2009: Safety machines

EMC:

- EN 61000-3-12:2005
- EN 61000-6-1:2007
- EN 61000-6-4:2007

Planned for 2013

USA - UL:

- UL 1004 P 1+4
- UL 1741
- UL 1283

Field Evaluation USA:

- NFPA 70
- NFPA 79
- UL 508a


Canada:

- C22.2.N6 100-04 (R2009): Motors and Generators
- C22.1-09: Canadian Electrical Code

Field Evaluation Canada:

- CSA SPE 1000 09: Code for Field Evaluation of el. equip.
- C22 NO 257-06 (R2011): Interconnecting Inverter based..

System Architecture of EMS



Optional approach DC feed in:
(to be designed later)

Replacement of
Inverter Board
by 400V_{DC} to 48 V_{DC}
Buck Converter

